
SESAA Esterhazy Station - March 2024 Summary Report

Pollu	utants	Month F	Records		24-Hour	Records		1-Hour Records				
Name	Conc.	Avg.	Uptime	Maximum		SAAQS	Exceed	Ma	aximum	SAAQS	Exceed	
Name	Unit	Conc.	Optime	Conc.	Time	Standard	Days	Conc.	Time	Standard	Hours	
NO	ppb	0.7	100.0%	2.0	Mar-8	-	-	15.5	Mar-08 09:00	-	-	
NO ₂	ppb	1.9	100.0%	10.5	Mar-8	106	0	32.8	Mar-08 05:00	159	0	
NOx	ppb	3.3	100.0%	12.7	Mar-8	-	-	37.0	Mar-08 05:00	-	-	
O ₃	ppb	32.6	100.0%	40.8	Mar-9	-	-	52.1	Mar-09 19:00	82	0	
$PM_{2.5}$	ug/m3	4.0	100.0%	7.6	Mar-9	28	0	16.3	Mar-13 03:00	-	-	


SAAQS: Saskatchewan Ambient Air Quality Standards



- *All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- *All compliance parameters were within the Saskatchewan Ambient Air Quality Standards.
- *All compliance parameters were above 90% operational.
- *Routine quarterly calibrations were completed on March 13, 2024




SESAA Esterhazy Station - March 2024 Summary Report




Parameters	Unit		Color Code for Wind Spd & Pollutant Conc. Class									
Wind Speed	m/s	0.3 ≤ WS < 1.4	1.4 ≤ WS < 3.1	3.1 ≤ WS < 7.8	7.8 ≤ WS < 10.8	10.8 ≤ WS < 13.6	WS ≥ 13.6					
NO ₂	ppb	0 ≤ C < 5	5 ≤ C < 15	15 ≤ C < 30	30 ≤ C < 100	100 ≤ C < 212	C ≥ 212					
PM _{2.5}	ug/m³	0 ≤ C < 2	2 ≤ C < 4	4 ≤ C < 10	10 ≤ C < 20	20 ≤ C < 30	C ≥ 30					
O ₃	ppb	0 ≤ C < 10	10 ≤ C < 20	20 ≤ C < 40	40 ≤ C < 60	60 ≤ C < 82	C ≥ 82					

SESAA Glen Ewen Station - March 2024 Summary Report

Pollu	utants	Month F	Records		24-Hour	Records		1-Hour Records				
Name	Conc.	Avg.	Uptime	Max	Maximum		Exceed	Ma	aximum	SAAQS	Exceed	
Ivallie	Unit	Conc.	Opune	Conc.	Time	Standard	Days	Conc.	Time	Standard	Hours	
NO	ppb	0.4	99.3%	1.2	Mar-8	-	-	5.1	Mar-09 09:00	-	-	
NO ₂	ppb	1.6	99.3%	6.2	Mar-9	106	0	16.6	Mar-09 05:00	159	0	
NOx	ppb	1.9	99.3%	6.9	Mar-9	-	-	17.4	Mar-09 07:00	-	-	
SO ₂	ppb	0.4	99.5%	3.0	Mar-7	48	0	17.2	Mar-11 16:00	172	0	
O ₃	ppb	35.7	99.5%	40.1	Mar-21	-	-	54.5	Mar-09 18:00	82	0	
H ₂ S	ppb	< 0.1	99.5%	< 0.1	-	3.6	0	2.6	Mar-20 15:00	11	0	



SESAA Glen Ewen Station - March 2024 Summary Report




Parameters	Unit		Color Code	for Wind Spd	& Pollutant Co	onc. Class	
Wind Speed	m/s	0.3 ≤ WS < 1.4	1.4 ≤ WS < 3.1	3.1 ≤ WS < 7.8	7.8 ≤ WS < 10.8	10.8 ≤ WS < 13.6	WS ≥ 13.6
SO ₂	ppb	0 ≤ C < 1	1 ≤ C < 5	5 ≤ C < 10	10 ≤ C < 57	57 ≤ C < 172	C ≥ 172
NO ₂	ppb	0 ≤ C < 5	5 ≤ C < 15	15 ≤ C < 30	30 ≤ C < 100	100 ≤ C < 212	C ≥ 212
O ₃	ppb	0 ≤ C < 10	10 ≤ C < 20	20 ≤ C < 40	40 ≤ C < 60	60 ≤ C < 82	C ≥ 82
H₂S	ppb	0 ≤ C < 1	1 ≤ C < 3.6	3.6 ≤ C < 5	5 ≤ C < 8	8 ≤ C < 10.8	C ≥ 10.8


- *All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- *All compliance parameters were within the Saskatchewan Ambient Air Quality Standards.
- *All compliance parameters were more than 90% operational.
- *1 hour of data was flagged as "analyzer failure" for NO/NO2/NOx due to negative data spike caused by analyzer turning back on.
- *4 hours of data was flagged as "power failure" for the whole station due to a power issue on March 20.
- *Routine quarterly calibrations were completed on March 19, 2024.

SESAA Oxbow Station - March 2024 Summary Report

Pollu	utants	Month F	Records		24-Hour	Records		1-Hour Records				
Name	Conc.	Avg.	Uptime	Max	imum	SAAQS	Exceed	Maximum		SAAQS	Exceed	
INAITIE	Unit	Conc.	Optime	Conc.	Time	Standard	Days	Conc.	Time	Standard	Hours	
NO	ppb	0.2	99.9%	0.5	Mar-11	-	-	2.5	Mar-08 12:00	-	-	
NO ₂	ppb	2.0	99.9%	4.8	Mar-8	106	0	9.3	Mar-09 00:00	159	0	
NOx	ppb	2.0	99.9%	5.1	Mar-8	-	-	10.0	Mar-09 00:00	-	-	
SO ₂	ppb	0.3	100.0%	1.2	Mar-5	48	0	4.1	Mar-05 12:00	172	0	
H ₂ S	ppb	0.2	100.0%	1.0	Mar-9	3.6	0	1.4	Mar-09 10:00	11	0	
$PM_{2.5}$	ug/m3	3.8	100.0%	9.6 Mar-9		28	0	18.1	Mar-09 20:00	-	-	



SESAA Oxbow Station - March 2024 Summary Report




Parameters	Unit		Color Code f	or Wind Spd	& Pollutant Co	nc. Class	
Wind Speed	m/s	0.3 ≤ WS < 1.4	1.4 ≤ WS < 3.1	3.1 ≤ WS < 7.8	7.8 ≤ WS < 10.8	10.8 ≤ WS < 13.6	WS ≥ 13.6
SO ₂	ppb	0 ≤ C < 1	1 ≤ C < 5	5 ≤ C < 10	10 ≤ C < 57	57 ≤ C < 172	C ≥ 172
NO ₂	ppb	0 ≤ C < 5	5 ≤ C < 15	15 ≤ C < 30	30 ≤ C < 100	100 ≤ C < 212	C ≥ 212
H ₂ S	ppb	0 ≤ C < 1	1 ≤ C < 3.6	3.6 ≤ C < 5	5 ≤ C < 8	8 ≤ C < 10.8	C ≥ 10.8
PM _{2.5}	ug/m³	0 ≤ C < 2	2 ≤ C < 4	4 ≤ C < 10	10 ≤ C < 20	20 ≤ C < 30	C ≥ 30


- *All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- *All compliance parameters were within the Saskatchewan Ambient Air Quality Standards.
- *All compliance parameters were greater than 90% operational.
- *1 hour of data flagged as "analyzer failure" for NO/NO2/NOx due to a spike in data.
- *Routine quarterly calibrations were completed on March 27, 2024.

SESAA Stoughton Station - March 2024 Summary Report

Pollu	Pollutants Month Records 24-Hour Records				1-Hour Ro	ecords					
Name	Conc.	Avg.	Uptime	Max	imum	SAAQS	Exceed	Ma	aximum	SAAQS	Exceed
INAITIE	Unit	Conc.	Optime	Conc.	Time	Standard	Days	Conc.	Time	Standard	Hours
NO	ppb	0.4	99.7%	3.2	Mar-14	•	-	34.2	Mar-14 11:00	•	
NO ₂	ppb	0.6	99.7%	3.0	Mar-8	106	0	14.9	Mar-14 11:00	159	0
NOx	ppb	0.9	99.7%	4.0	Mar-8	-	-	49.1	Mar-14 11:00	-	-
SO ₂	ppb	0.3	99.6%	1.6	Mar-9	48	0	5.2	Mar-09 15:00	172	0
H ₂ S	ppb	0.1	99.6%	0.4	Mar-12	3.6	0	0.6	Mar-06 21:00	11	0
$PM_{2.5}$	ug/m3	2.3	65.2%	9.7	Mar-13	28	0	27.6	Mar-13 17:00	-	-



SESAA Stoughton Station - March 2024 Summary Report




- *All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- *All compliance parameters were within the Saskatchewan Ambient Air Quality Standards.
- *All compliance parameters were above 90% operational, except PM2.5.
- *259 hours of data flagged as "analyzer failure" for PM2.5 due to unusual spikes and plateaus from March 1 to March 11.
- *1 hour of data flagged as "analyzer failure" for H2S and SO2 due to flatlined data.
- *2 hours of data flagged as "maintenance" for H2S, NO/NO2/NOx and SO2 due to manual spans triggered on March 28.
- *Routine quarterly calibrations were completed on March 11, 2024.

SESAA Torquay Station - March 2024 Summary Report


Pollu	utants	Month F	Records		24-Hour	Records		1-Hour Records				
Nama	Name Conc. Avg. Uptime		Untimo	Maximum		SAAQS	Exceed	Maximum		SAAQS	Exceed	
INAIIIE	Unit	Conc.	Opullie	Conc.	Time	Standard	Days	Conc.	Time	Standard	Hours	
SO ₂	ppb	0.2	99.3%	1.3	Mar-5	48	0	12.0	Mar-05 16:00	172	0	
H ₂ S	ppb	< 0.1	99.3%	0.2	Mar-12	3.6	0	0.9	Mar-10 22:00	11	0	
PM _{2.5}	ug/m3	3.3	99.3%	14.1	Mar-13	28	0	33.8	Mar-13 15:00	-		


SAAQS: Saskatchewan Ambient Air Quality Standards



- *All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- *All compliance parameters were within the Saskatchewan Ambient Air Quality Standards.
- *All compliance parameters had greater than 90% operational uptime.
- *5 hours of data for the whole station flagged as "power failure" due to power issues causing flatlined data.
- *Routine quarterly calibrations were completed on March 25, 2024.

SESAA Torquay Station - March 2024 Summary Report






Parameters	Unit		Color Code for Wind Spd & Pollutant Conc. Class								
Wind Speed	m/s	0.3 ≤ WS < 1.4	1.4 ≤ WS < 3.1	3.1 ≤ WS < 7.8	7.8 ≤ WS < 10.8	10.8 ≤ WS < 13.6	WS ≥ 13.6				
SO ₂	ppb	0 ≤ C < 1	1 ≤ C < 5	5 ≤ C < 10	10 ≤ C < 57	57 ≤ C < 172	C ≥ 172				
NO ₂	ppb	0 ≤ C < 5	5 ≤ C < 15	15 ≤ C < 30	30 ≤ C < 100	100 ≤ C < 212	C ≥ 212				
O ₃	ppb	0 ≤ C < 10	10 ≤ C < 20	20 ≤ C < 40	40 ≤ C < 60	60 ≤ C < 82	C ≥ 82				
H ₂ S	ppb	0 ≤ C < 1	1 ≤ C < 3.6	3.6 ≤ C < 5	5 ≤ C < 8	8 ≤ C < 10.8	C ≥ 10.8				
PM _{2.5}	ug/m³	0 ≤ C < 2	2 ≤ C < 4	4 ≤ C < 10	10 ≤ C < 20	20 ≤ C < 30	C ≥ 30				

SESAA Wauchope Station - March 2024 Summary Report

Pollu	utants	Month F	Records		24-Hour	Records		1-Hour Records			
Name	Conc.	Avg.	Uptime	Intimo Maxir		num SAAQS		Ma	aximum	SAAQS	Exceed
Ivaille	Unit	Conc.	Optime	Conc.	Time	Objective	Days	Conc.	Time	Objective	Hours
SO ₂	ppb	0.2	100.0%	1.3	Mar-9	48	0	4.6	Mar-09 11:00	172	0
H ₂ S	ppb	0.1	100.0%	0.1	Mar-28	3.6	0	1.8	Mar-25 03:00	11	0
PM _{2.5}	ug/m3	4.2	99.9%	11.7	Mar-9	28	0	26.9	Mar-09 14:00	-	-



SESAA Wauchope Station - March 2024 Summary Report


Parameters	Unit		Color Code f	or Wind Spd	& Pollutant C	onc. Class	
Wind Speed	m/s	0.3 ≤ WS < 1.4	1.4 ≤ WS < 3.1	3.1 ≤ WS < 7.8	7.8 ≤ WS < 10.8	10.8 ≤ WS < 13.6	WS ≥ 13.6
SO ₂	ppb	0 ≤ C < 1	1 ≤ C < 5	5 ≤ C < 10	10 ≤ C < 57	57 ≤ C < 172	C ≥ 172
H ₂ S	ppb	0 ≤ C < 1	1 ≤ C < 3.6	3.6 ≤ C < 5	5 ≤ C < 8	8 ≤ C < 10.8	C ≥ 10.8
PM _{2.5}	ug/m³	0 ≤ C < 2	2 ≤ C < 4	4 ≤ C < 10	10 ≤ C < 20	20 ≤ C < 30	C ≥ 30

- *All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- *All compliance parameters were within the Saskatchewan Ambient Air Quality Standards.
- *All compliance parameters were greater than 90% operational.
- *1 hour of data for PM2.5 was flagged as "analyzer failure" due a spike in data.
- *Non-routine calibrations were completed on March 18, 2024 due to SO2 and H2S spans being out of range.


SESAA Weyburn Station - March 2024 Summary Report

Pollu	utants	Month F	Records		24-Hour	Records		1-Hour Records				
Name	Conc.	Avg.	Uptime	Max	imum	SAAQS	Exceed	M	aximum	SAAQS	Exceed	
Ivallie	Unit	Conc.	Optime	Conc.	Time	Standard	Days	Conc.	Time	Standard	Hours	
NO	ppb	0.3	94.9%	0.9	Mar-8	-	-	4.9	Mar-05 09:00	-	-	
NO ₂	ppb	1.0	94.9%	2.3	Mar-8	106	0	7.2	Mar-05 06:00	159	0	
NOx	ppb	1.3	94.9%	3.2	Mar-8	-	-	10.4	Mar-05 08:00	-	-	
SO ₂	ppb	1.3	90.7%	11.0	Mar-8	48	0	39.6	Mar-08 09:00	172	0	
O ₃	ppb	31.9	99.7%	37.7	Mar-20	-	-	48.0	Mar-09 16:00	82	0	
H ₂ S	ppb	0.3	90.7%	1.5	Mar-8	3.6	0	11.0	Mar-31 06:00	11	0	
PM _{2.5}	ug/m3	0.5	99.7%	3.4	Mar-28	28	0	14.9	Mar-28 09:00	-	-	

^{*} Air Quality Standard refers to Saskatchewan Ambient Air Quality Standards (SAAQS).



SESAA Weyburn Station - March 2024 Summary Report



- *All data has been slope, intercept, and baseline corrected. Data may change after validation process.
- *All compliance parameters were within the Saskatchewan Ambient Air Quality Standards.
- *All compliance parameters were above 90% operational.
- *2 hours of data for all parameters was flagged as "power failure" due to power issues causing flatlines and spikes.
- *33 67 hours of data for the whole station was flagged as "analyzer failure" due to data spikes and plateaus from Mar 15 to Mar 20.
- *Routine calibrations occurred on March 26, 2024.